

**GOVERNMENT OF THE DISTRICT OF COLUMBIA
DEPARTMENT OF GENERAL SERVICES**

Engine Company 30 Renovations and Upgrades

Solicitation No.: DCAM-15-CS-0122

**Amendment No. 7
Issued: June 12, 2015**

This Amendment No. 7 is issued and hereby published on the DGS website on June 12, 2015. Except as modified hereby, the Request for Proposals ("RFP") remains unmodified.

Item #1 Questions and Answers Regarding Solicitation

Responses to questions are attached to this Amendment as Exhibit 1.

Supporting Documents:

Exhibit 1- Response to Questions

By:



James Marshall
Supervisory Contracting Specialist

Date:

6.12.15

1	Section B.2.2.12	<p>Section B.2.2.12 calls out a refrigerator room (119), but there is no such room on the drawings. The scope of work is extensive, including modification of the layout of CMU/Masonry walls, all to receive a skim after renovation, replacing an existing door & frame with higher level security hardware required, new occupancy sensors and light switches.</p> <p>In most instances, the door number matches the room number, but door 119 in the drawings is existing to remain and the room it enters is a fitness room.</p>	Section B2.2.12 should read "Fitness Room"
2	Section B.2.2.17	<p>Section B.2.2.17 calls out the basement, but there are no drawings for a basement. The scope of work is extensive, including new doors with higher level security hardware required, a new circuit for the sump pump, changing 4 light fixtures, and hydro jetting an exterior floor drain.</p>	There are no existing drawings for the basement. There is only one door. The scope of work is consistent with other rooms.
3		Door 103 is ETR, but the schedule shows it to receive a new closer, while the scope of work calls out a new kick plate and closer.	Include a new kick plate and closer
4		Door 104 is ETR and calls out a new door closer, but it is not mentioned anywhere in the scope of work	Include a door closer for door 104
5		Door 114 on the door schedule shows that it is to receive a new closer and hardware, but it is not mentioned in the scope of work	See Section B.2.2.16 (6) of RFP
6		Doors 133 and 123 are both scheduled for new hardware in the schedule, but not mentioned in the scope of work	Include new hardware for doors 133 and 123
7	B.2.2.24	Also we would like to better understand what is expected by the scope item B.2.2.24 "polish terrazzo"; is that a scrub/strip/seal or a mechanical grinding/polishing and re-grout?	Scrub/strip/seal